



BIOPIPE PILOT PLANT SAMPLE ANALYSIS

Date	Time	COMMON INFLUENT (Grab Sample)														HORIZONTAL TYPE							DM STANDARD IN mg/L						
									MODULE - 1 OUTLET							MODULE - 2 OUTLET							TDS (mg/l)	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)	NH3-N (mg/l)	FRC (mg/l)
		TDS (mg/l)	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)	NH3-N (mg/l)	TDS (mg/l)	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)	NH3-N (mg/l)	TDS (mg/l)	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)	NH3-N (mg/l)	FRC (mg/l)	1500	6.0-8.0	10	50	20	1.0	0.5-1.0		
06.01.18	12:40pm	1930	7.01	224	670	N/A	27.9	2229	7.23	45	97	N/A	25.0	2086	7.23	18	37	N/A	0.2	NIL									
10.01.18	01:40pm	2369	7.03	256	652	N/A	23.6	2478	7.14	77	158	N/A	21.7	2325	7.14	21	43	N/A	0.2	NIL									
18.01.18	08:50am	2034	7.14	267	718	N/A	30.4	2143	7.19	83	170	N/A	23.1	2088	7.18	19	29	N/A	0.4	NIL									

Contact:
Biopipe Global Corp. USA
 100 Challenger Road, 8th Floor
 Ridgefield Park, NJ 07660
 info@lifequestcorp.com
 +1 646-201-5242